

HAMPAPURA POWER TRANSMISSION LIMITED

Office Address: RMZ Infinity, 5th Floor, Plot No 15, Udyog Vihar, Gurugram, Haryana 122015.

NOTICE

(Under sub-section (2) of Section 15 of the Electricity Act, 2003)

1. **HAMPAPURA POWER TRANSMISSION LIMITED**, having its office at, **RMZ Infinity, 5th Floor, Plot No 15, Udyog Vihar, Gurugram, Haryana 122015** which is incorporated under the Companies Act, 1956 has made up an application before the Karnataka Electricity Regulatory Commission, Bengaluru under sub section (1) of Section 15 of the Electricity Act, 2003 for grant of transmission license in respect of the transmission lines, sub stations and other assets, the details of which are given;

Amount in Rs. Million

Sl. No	Name of the line/ substation (location)	Line Length/Capacity	Quoted Transmission Charges	Schedule COD	Remarks
1.	Establishing 2x500 MVA, 400/220/33 kV GIS sub station at Hampapura in Mandya Taluk & District. Space For Future Provision • 500 MVA, 400/220/33 kV ICTs: 4 Nos. • 400 kV ICT Bay: 4 Nos. • 420 kV, 125 MVAR bus reactors: 2 Nos. • 400 kV Line Bays: 4 Nos. • 220 kV ICT Bay: 4 Nos. • 220 kV Line bays: 8 Nos. • 400 kV Bus Reactor Bay – 2 Nos.	• 500 MVA, 400/220/33 kV ICTs: 2 Nos. • 400 kV ICT Bay: 2 Nos. • 420 kV, 125 MVAR bus reactors: 2 Nos. • 400 kV Line Bays: 4 Nos. (for termination of LILO of 400kV DC Quad moose line from Jagalur- Kadakola to 400/220 kV Hampapura sub-station) • 220 kV ICT Bay: 2 Nos. • 220 kV Line bays: 8 Nos. • 220 kV Bus-Sectionalizer Bay – 1 Set • 220 kV Bus- coupler Bay - 2 Nos • 400 kV Bus Reactor Bay – 2 NOS • 400Kv Bus PT bay – 2 Nos • 220 KV Bus PT bay 4 nos	Rs. 4,029.16 Million	24 Months	
2.	400kV DC Quad moose line from Jagalur- Kadakola with LILO to 400/220 kV Hampapura sub-station				
3.	LILO of 400kV DC Quad moose line from Jagalur- Kadakola to proposed 765/400kV CN'Halli Station (under ISTS scheme)	• 400 kV Line bays at proposed 765/400kV CN'Halli Station: 4 Nos.			
4.	220 kV DC line with Twin Zebra conductor from proposed Hampapura to 220/66kV Huygonahalli sub station along with 2 nos of 220kV TB's at Huygonahalli	• 220 kV Line bays at 220/66kV Huygonahalli sub station: 2 Nos. (for termination of Hampapura to 220/66kV Huygonahalli Hampapura to 220/66kV Huygonahalli			
5.	220 kV DC line with Twin Zebra conductor from proposed Hampapura to 220/66kV Tubinakere sub station along with 2 nos of 220kV TB's at Tubinakere	• 220 kV Line bays at 220/66kV Tubinakere sub station: 2 Nos. (for termination of Hampapura to 220/66kV Tubinakere 220 kV DC line)			
6.	220 kV DC line with Twin Zebra conductor from proposed Hampapura to proposed 220/66kV Maddur sub-station along with 2 nos of 220kV TB's at proposed Maddur	• 220 kV Line bays at proposed 220/66kV Maddur sub-station: 2 Nos. (for termination of Hampapura to proposed 220/66kV Maddur 220 kV DC line)			
7.	220 kV DC line with Twin Zebra conductor from proposed Hampapura to 220/66kV Nagamangala sub-station along with 2 nos of 220kV TB's at Nagamangala	• 220 kV Line bays at 220/66kV Nagamangala: 2 Nos. (for termination of Hampapura to 220/66kV Nagamangala 220 kV DC line)			

2. Complete application and other documents filed before the Commission are available on the website <https://resonia.com> for access of any person. The application can also be inspected at the office of the Company RMZ Infinity, 5th Floor, Plot No 15, Udyog Vihar, Gurugram, Haryana 122008 with Mr. T. Amarendranath Reddy or Office of the Commission in accordance with the procedure specified by the Commission.
3. Objections and suggestions, if any, be filed before the Secretary, Karnataka Electricity Regulatory Commission No.16, C-1, Miller Tank Bed Area, Vasanthanagar, Bengaluru - 560052, with a copy of objection(s)/suggestion(s) to the applicant or its authorised agent within 15 days of publication of this notice in the newspaper.

Place: Gurgaon
Date: 11.06.2026

Mr. T. Amarendranath Reddy
Director
Hampapura Power Transmission Limited